

Approved body No. 1121

Certificate of constancy of performance

1121-CPR-UK-ABB7801

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

“5760.60 Escape Lock Range” Emergency Exit Device

Intended use:- For use on single leaf escape route doors, including fire resisting / smoke control doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical Test Evidence : WIL 512116 Fire Test Evidence : 347332 Iss 4 / 413358 Iss 2 / 416170 / 417357 417360 & 422917 Iss 3	
Clause 4.2.1 Ability to release (for doors on escape routes) Release function Lever handle Single doorset Double doorset Exposed edges and corners Lever handle installation Operating element projection Operating element face (Lever handle) Lever handle operating gap Test rod Accessible gap Door free movement Top vertical bolt Keepers Keepers dimensions Door mass and dimensions Outside access device Release forces Security requirement	< 1 sec Pass Pass NPD Pass X > 120mm & Z < 150mm W < 100mm V > 18mm / free end U > 40mm / W < 100mm, a < 30° Pass Pass Pass Pass NPD Pass NPD Door mass ≤ 200 Kg, door height ≤ 2500 mm, door width ≤ 1300 mm Pass Type A < 70 N Grade 4	EN 179:2008
Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on escape routes) Corrosion resistance Temperature range Lubrication Re-engagement force Durability Abuse resistance –lever handle Final examination	Grade 4 : 240 hours Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C° Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 500 N & 1000N Type A < 70 N	

Certificate of constancy of performance

1121-CPR-UK-ABB7801

Clause 4.2.1 Self closing ability C (for fire/smoke doors on escape routes) Re-engagement force	< 50 N	
Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on escape routes) Durability Re-engagement force	Grade 7: 200 000 cycles < 50 N	
Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire doors on escape routes) Suitability of panic exit devices for use on fire resisting doorsets assemblies - Additional requirements	Grade B : Suitable for use on fire/smoke single door assemblies.	
Clause 4.1.25 Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the device do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	

Lever Handle Model Numbers	Single Door	Lock Reference 5760.60.R.SS	Lock Reference 5760.60.S.SS	For fire door use
Allegion				
4701.22.140	Yes	√	√	√
4701.20.140	Yes	√	√	√
4201.19	Yes	√	√	√
4702BP.B.22.140	Yes	√	√	√
4702BP.EC.B.22.140	Yes	√	√	√
Accessories				
5500/989/00/A Split spindle and half spindle				

Certificate of constancy of performance

1121-CPR-UK-ABB7801

Placed on the market under the name of

Allegion (UK) Ltd
35 Rocky Lane, Aston, Birmingham, B6 5RQ

and produced in the manufacturing plant

J/311

This is coded format and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 179 : 2008

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **20/06/2022** and reissued **20/08/2022** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **19/06/2025**



Paul Duggan
Certification Manager



Warringtonfire Testing and Certification Ltd
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK